

**REGULAR MEETING OF THE KIMBERLY WATER COMMISSION**  
**MINUTES**  
**June 9, 2026**

Chairman Johnson called the meeting to order at 11:00 am. Commissioners Hanson and Hietpas appeared in person. Commissioner Stienen was absent. Also attending the meeting were Administrator/Public Works Director Block, Water Superintendent Verstegen, and Utility Billing Clerk Brown.

**Approval of Minutes from the May 12, 2026, Meeting**

Commissioner Hanson moved, Hietpas seconded the motion to approve the Water Commission minutes of the May 12, 2026, meeting. The motion carried by unanimous vote of the Commission.

**Unfinished Business**

Administrator/Public Works Director Block informed the Water Commission of the Village's intent to apply for 2027 funds for the Safe Drinking Water Loan Program. McMahon will be helping with the application process, as the deadline to apply is June 30, 2026. The Village Board passed a resolution to help cover the cost of the grant, by borrowing bonds to cover those costs, if grant funds were to fall through or aren't enough to cover.

**New Business**

**Bills and Claims, and Financial Statements for the month of April-2026**

Commissioner Hietpas moved, Hanson seconded the motion to accept the Bills, Claims, and Financial Statements for April 2026.

**Reports**

**Superintendent's Report**

Superintendent Verstegen noted in his report that part of his budget was to replace resins for well's #1 and #3. There is a resin shortage, so costs have increased. He's working on getting a firm cost estimate.

There are continuing air issues with well #1. The department is trying to pinpoint the problem.

Superintendent Verstegen informed the commission that he is currently working with the DNR regarding various certifications.

Meter changes continue, with 2<sup>nd</sup> and 3<sup>rd</sup> notices being sent to customers.

## **Request for Consideration-McMahon Corrosion Control Engineering Services**


Superintendent Verstegen presented a Request for Consideration to review and approve McMahon Corrosion Control Engineering Services. It's a two-part analysis and recommendation to the Village Board for switching from sodium silicate to a blended phosphate product. If passed, it will then go to the DNR for submittal. The proposed cost is \$31,500.00.

### **Public Participation**

None

### **Adjournment**

Commissioner Hanson moved, Hietpas seconded the motion to adjourn. The motion carried by unanimous vote and the Commission adjourned at 11:22 am.



Danielle Block  
Secretary

Dated June 16, 2026

Drafted by SKB

Approved by Water Commission on 7-14-26